

Issued by : NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands

Applicant : Itron
Ganz Meter Company Ltd.
Tancsics Mihaly u. 11
H-2100 Gödöllő
Hungary

Submitted : **Static electrical energy meter**

Manufacturer : Itron
Type : SL761X...

Characteristics : See page 2

In accordance with :

- IEC 62052-11** "Electricity metering equipment (AC) - General requirements, tests and test conditions - Part 11: Metering equipment"
- IEC 62053-22** "Electricity metering equipment (AC) - Particular requirements - Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)"
- IEC 62053-21** "Electricity metering equipment (AC) - Particular requirements - Part 21: Static meters for active energy (classes 1 and 2)"
- IEC 62053-23** "Electricity metering equipment (AC) - Particular requirements - Part 23: Static meters for reactive energy (classes 2 and 3)"
- IEC 62053-24** "Electricity metering equipment (AC) - Particular requirements - Part 24: Static meters for reactive energy at fundamental frequency (classes 0,5 S, 1 S and 1)"
- EN 50470-1** "Electricity metering equipment (a.c.) - General requirements, tests and test conditions - Part 1: Metering equipment (class indexes A, B and C)"
- EN 50470-3** "Electricity metering equipment (a.c.) - Particular requirements - Part 3: Static meters for active energy (class indexes A, B and C)"
- CLC/TR 50579** "Electricity metering equipment - Severity levels, immunity requirements and test methods for conducted disturbances in the frequency range 2-150 kHz"

The undersigned declares that the described product is tested according to the above mentioned standards and meet their requirements, based on a non-recurrent examination. The appertaining test data is presented in the type evaluation report no. NMI-11200858-01, NMI-11200858-02, NMI-11200858-03, NMI-11200858-04, NMI-11200858-05, NMI-11200858-06, NMI-13200138-01, NMI-13200462-01 and NMI-1901679-01, granted by NMI and used for EU-type examination certificate T10710.

NMI Certin B.V.
15 November 2019

Certification Board

Characteristics of the measuring instrument

The general characteristics of the measuring instrument are presented.

| | | | | | | | | | | | | | | | | |
|---------------------------------|--|-------------------|------------|-----------------|----------------|--------------|-----------------|---|--------------|-----------------|---|--------------|-------------------|-------|--------------|-------------------|
| Model | SL761X... | | | | | | | | | | | | | | | |
| Accuracy class | <table border="0"> <tr> <td>B or C</td> <td>EN 50470-3</td> <td>(Active energy)</td> </tr> <tr> <td>0,2 S or 0,5 S</td> <td>IEC 62053-22</td> <td>(Active energy)</td> </tr> <tr> <td>1</td> <td>IEC 62053-21</td> <td>(Active energy)</td> </tr> <tr> <td>2</td> <td>IEC 62053-23</td> <td>(Reactive energy)</td> </tr> <tr> <td>0,5 S</td> <td>IEC 62053-24</td> <td>(Reactive energy)</td> </tr> </table> | B or C | EN 50470-3 | (Active energy) | 0,2 S or 0,5 S | IEC 62053-22 | (Active energy) | 1 | IEC 62053-21 | (Active energy) | 2 | IEC 62053-23 | (Reactive energy) | 0,5 S | IEC 62053-24 | (Reactive energy) |
| B or C | EN 50470-3 | (Active energy) | | | | | | | | | | | | | | |
| 0,2 S or 0,5 S | IEC 62053-22 | (Active energy) | | | | | | | | | | | | | | |
| 1 | IEC 62053-21 | (Active energy) | | | | | | | | | | | | | | |
| 2 | IEC 62053-23 | (Reactive energy) | | | | | | | | | | | | | | |
| 0,5 S | IEC 62053-24 | (Reactive energy) | | | | | | | | | | | | | | |
| Destined for the measurement of | electrical energy, in a - three-phase four-wire system - three-phase three-wire system | | | | | | | | | | | | | | | |
| U_{ref} | 3x57,7/100 V... 3x277/480 V | | | | | | | | | | | | | | | |
| I_b | 1 A | | | | | | | | | | | | | | | |
| I_{max} | 10 A | | | | | | | | | | | | | | | |
| f_{ref} | 50 Hz or 60 Hz | | | | | | | | | | | | | | | |
| Temperature range | -40 °C / +70 °C | | | | | | | | | | | | | | | |
| Degree of protection | IP51 | | | | | | | | | | | | | | | |
| Software loader | 01.00j Checksum: 0x1D5510C5 | | | | | | | | | | | | | | | |
| Metrology software version | 07.01c Checksum: 0xF127A15 07.02a Checksum: 0xF127816 07.03a Checksum: 0xF3C2AE4 07.04a Checksum: 0xf44179a | | | | | | | | | | | | | | | |
| Application software version | 07.14a.00 Checksum: 0x62A347FA 07.23d.00 Checksum: 0x75C750C6 07.24b.00 Checksum: 0x761145E1 07.25a.00 Checksum: 0x769C0246 07.26d.00 Checksum: 0x8D2DED8F 07.26e.00 Checksum: 0x8D553D73 07.26g.00 Checksum: 0x8D69C3B6 07.30b.00 Checksum: 0x93CCBE5D 07.31b.00 Checksum: 0x95B3F592 07.32a.00 Checksum: 0x963008CA 07.33b.00 Checksum: 0x9681CED7 07.33c.00 Checksum: 0x976EE9E4 07.42b.00 Checksum: 0xb19993b1 07.51e.00 Checksum: 0xb15d6d96 07.53f.00 Checksum: 0xb247dc7b | | | | | | | | | | | | | | | |
| Hardware version (main board) | A206172 AD A206172 AE A206172 AF A206172 AG | | | | | | | | | | | | | | | |
| Hardware version (PSU board) | A205974 AC A205974 AD A205972 AC A205971 AC A209034 AB | | | | | | | | | | | | | | | |