

## CE Declaration of conformity

We,

Actaris  
ZI de Chasseneuil, avenue des temps modernes  
86361 Chasseneuil du Poitou – FRANCE

ISO 9001 certified by AFAQ

Declare that the products:

SMART Commercial & Industrial Meter SL761A and SL761B :

- 3-phase 4-wire system :
  - voltage 3x57.7/100V 3x63.5/110V 3x127/220V 3x220/380V 3x230/400V 3x240/415V
- 3-phase 3-wire system :
  - voltage 3x100V 3x110V 3x220V 3x380V 3x400V 3x415V
  - 1(10A)
  - 50 Hz

Provide that it is installed, maintained and used in the application for which it is made, with respect of the « profession's practices », relevant installation standards and manufacturer's instructions, complies with the provisions of Council Directive(s) :

- 89/336/CEE, 92/31/CEE, 93/68/CEE

and is conformity with the following harmonised standards or other normative documents :

- ≡ EN 62052-11 Electricity metering equipment (AC) : General requirements
- ≡ EN 62053-22 Electricity metering equipment (AC) : Particular requirements-Active energy (class 0.2 S and 0.5 S)
- ≡ EN 62053-23 Electricity metering equipment (AC) : Particular requirements-Reactive energy (class 2)
- ≡ EN 62054-21 Electricity metering (AC) : Particular requirements for time switches  
( NMI test report : CVN-501143-02)

Additional information:

The technical file is available for consultation in Chasseneuil.

Date of affixing « CE » marking: 13<sup>th</sup> July 2005

Signature : J.TALBOT  
Design Quality Manager

